

PFAS

Submitted - Signed

PWS ID #: 4133002 City/Town: HOLBROOK

PWS Name: BLUEDROP WATER @ STANNESYS VENDING

PWS Class: TNC

Primary Lab MA Cert #: MA030 Primary Lab Name: ALPHA ANALYTICAL

Location ID: 10000 Location: DISPENSING NOZZLE M/S: S D R/F: RS Collected By: James MacLaine Collection Date: 4/11/2023 O/R/C: O Resubmit Reason: Original Collection:

Sample Comments: Lab Sample ID: L2319429-01 Sample Composted: N Composite Sample Comments:

Analytical Method: EPA 537.1 Analytical Lab ID: MA030 Analytical Lab: ALPHA ANALYTICAL Analysis Date: 4/21/2023 Extraction date: 4/20/2023 Analysis Comments:

QA/QC Method 1: PERFLUORO-N-(1,2-13C2)HEXANOIC ACID (13C-PFHXA) 119 QA/QC Result 1: 4/21/2023 QA/QC Method 2: 4/20/2023 QA/QC Result 2: 113

QA/QC Method 3: PERFLUORO-N-(1,2-13C2)DECANOIC ACID (13C-PFDA) 122 QA/QC Result 3: 4/21/2023 QA/QC Method 4: N-DEUTERIOETHYLPERFLUORO-1-OCTANESULFONAMIDODACETIC ACID (D5-NETFOSAA) 134 QA/QC Result 4: 4/21/2023

CAS #	Contaminant:	Result:	UOM:	MCL (ORSG):	MDL:	MRL:	Dilution Factor	Result Qualifier	Result Qualifier Description
Regulated Contaminants									
335-76-2	PERFLUORODECANOIC ACID - PFDA	ND	NG/L	0.613	2.00		1		
375-85-9	PERFLUOROHEPTANOIC ACID-PFHPA	ND	NG/L	0.613	2.00		1		
355-46-4	PERFLUOROHEXANESULFONIC ACID-PFHXS	ND	NG/L	0.613	2.00		1		
375-95-1	PERFLUORONONANOIC ACID-PFNA	ND	NG/L	0.613	2.00		1		
1763-23-1	PERFLUOROOCETANESULFONIC ACID-PFOS	ND	NG/L	0.613	2.00		1		
335-67-1	PERFLUOROOCETANOIC ACID-PFOA	ND	NG/L	0.613	2.00		1		
NONE	PFAS6	ND	NG/L	20	2.00		1		
Unregulated Contaminants									
763051-92-9	11-CHLOROETHANESULFONIC ACID	ND	NG/L	0.613	2.00		1		

M/S = Multiple or Single sources represented in sample site.

D/S = Distribution or Source sample site.

R/F = Raw or Finished water sample site.

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4133002
 PWS Name: BLUEDROP WATER @ STANNESYS VENDING

4/24/2023 6:52:52 AM
 Page 1 of 2