

**PFAS**

**Submitted - Signed**

PWS ID #: 4133003 City/Town: HOLBROOK

PWS Name: BLUEDROP WATER @ BROOKVILLE CHURCH

PWS Class: TNC

Primary Lab MA Cert #: MA030 Primary Lab Name: ALPHA ANALYTICAL

Location ID: 10000 Location: FINISHED WATER M/S: S D D/S: R/F: Routine/ Special: Collected By: James Maclane Collection Date: 7/28/2022 O/R/C: 0 Resubmit Reason: Original Collection:

Sample Comments: Lab Sample ID: L2240477-01 Sample Composed: N Composite Sample Comments: Analysis Date: 8/2/2022 Extraction date: 8/2/2022 Analysis Comments:

Analytical Method: EPA 537.1 Analytical Lab ID: MA030 Analytical Lab: ALPHA ANALYTICAL

QA/QC Method1:	QA/QC Result1:	QA/QC Method 2:	QA/QC Result 2:
2,3,3,3-TETRAFLUORO-2(1,1,2,2,3,3,3-HEPTAFLUOROPROPXY)-13C3-PROPANOIC ACID (M3HFPO-DA)	89	PERFLUORO-N(1,2-13C2)DECANOIC ACID (13C-PFDA)	85
QA/QC Method3:	QA/QC Result3:	QA/QC Method4:	QA/QC Result4:
N-DEUTERIOETHYLPERFLUORO-1-OCTANESULFONAMIDOCACETIC ACID (D5-NETFOSAA)	84	PERFLUORO-N(1,2-13C2)HEXANOIC ACID (13C-PFHXA)	94

CAS #	Contaminant:	Result:	UOM:	MCL (ORSG):	MDL:	MRL:	Dilution Factor	Result Qualifier	Result Qualifier Description
-------	--------------	---------	------	-------------	------	------	-----------------	------------------	------------------------------

**Regulated Contaminants**

335-76-2	PERFLUORODECANOIC ACID - PFDA	ND	NG/L	0.605	2.00	1			
375-85-9	PERFLUOROHEPTANOIC ACID-PFHPA	ND	NG/L	0.605	2.00	1			
365-46-4	PERFLUOROHEXANESULFONIC ACID-PFHXS	ND	NG/L	0.605	2.00	1			
375-95-1	PERFLUORONONOANOIC ACID-PFNA	ND	NG/L	0.605	2.00	1			
1763-23-1	PERFLUOROOCCTANESULFONIC ACID-PFOS	ND	NG/L	0.605	2.00	1			
335-67-1	PERFLUOROOCCTANOIC ACID-PFOA	ND	NG/L	0.605	2.00	1			
NONE	PFAS6	ND	NG/L	20	2.00	1			
<b>Unregulated Contaminants</b>									
763051-92-9	11-CHLOROEOCOSAFLUORO-3-	ND	NG/L	0.605	2.00	1			

M/S = Multiple or Single sources represented in sample site.  
 D/S = Distribution or Source sample site.  
 R/F = Raw or Finished water sample site.  
 MDL = Method Detection Limit.  
 UOM = Unit of Measurement.  
 O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4133003  
 PWS Name: BLUEDROP WATER @ BROOKVILLE CHURCH

8/16/2022 9:45:01 AM  
 Page 1 of 2

**PFAS**

**Submitted - Signed**

919005-14-4	OXAUDECANE-1-SULFONIC ACID-11CL-PF30UDS	ND	NG/L	0.605	2.00	1
766426-66-1	4,8-DIOXA-3H-PERFLUORONONANOIC ACID - ADONA	ND	NG/L	0.605	2.00	1
13252-13-6	9-CHLOROHEXADECANFLUORO-3-OXANONE-1-SULFONIC ACID-9CL-PF30NS	ND	NG/L	0.605	2.00	1
2991-60-6	HEXAFLUOROPROPYLENE OXIDE DIMER ACID - HFPO-DA	ND	NG/L	0.605	2.00	1
2365-31-9	N-ETHYL PERFLUOROOCTANESULFONAMIDOACET IC ACID - NETFOSAA	ND	NG/L	0.605	2.00	1
375-73-5	N-METHYL PERFLUOROOCTANESULFONAMIDOACET IC ACID - NMIFOSAA	ND	NG/L	0.605	2.00	1
307-66-1	PERFLUOROBUTANESULFONIC ACID-PFBS	ND	NG/L	0.605	2.00	1
307-24-4	PERFLUORODODECANOIC ACID - PFDOA	ND	NG/L	0.605	2.00	1
376-06-7	PERFLUOROHEXANOIC ACID - PFHXA	ND	NG/L	0.605	2.00	1
72629-94-8	PERFLUOROTETRADECANOIC ACID - PFTA	ND	NG/L	0.605	2.00	1
2058-94-8	PERFLUOROTRIDECANOIC ACID - PFTRDA	ND	NG/L	0.605	2.00	1
	PERFLUOROUNDECANOIC ACID - PFUNA	ND	NG/L	0.605	2.00	1

Primary Lab Signature: Joseph Watkins

Date: 8/16/2022

EDEP Transaction ID: 1416638

Certified Signer User Name: JLVWATKINS

M/S = Multiple or Single sources represented in sample site.  
 D/S = Distribution or Source sample site.  
 R/F = Raw or Finished water sample site.  
 MDL = Method Detection Limit.  
 UOM = Unit of Measurement.

PWS ID #: 4133003  
 PWS Name: BLUEDROP WATER @ BROOKVILLE CHURCH

8/16/2022 9:45:01 AM  
 Page 2 of 2